

2023 Annual Drinking Water Quality Report
Village of Aurora
456 Main Street, Aurora, NY 13026
(Public Water Supply ID#0501714)

INTRODUCTION

To comply with State regulations, **the Village of Aurora** will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Mike White, Village DPW, at (315) 364-5239 or email aurorah2o@auroranewyork.us**. We want you to be informed about your drinking water.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves a population of 740 through 220 metered connections. Wells College draws its water from Cayuga Lake, the water is then filtered through Diatomaceous Earth filters and disinfected by injection of sodium hypochlorite solution before entering the distribution system. Any water not consumed by our customers is then stored in two storage tanks. A 300,000 gallon glass-lined tank located on Sherwood Rd. east of the village and a 150,000 gallon welded steel elevated tank located on the campus of Wells College. The portion of Cayuga Lake where the intake for the Filtration Plant is located is listed as a Class AA Special Water body by the NYSDEC and is considered to be an excellent source of drinking water.

NEW YORK STATE DEPARTMENT OF HEALTH SOURCE WATER ASSESSMENT

The NYS Department of Health has completed a source water assessment for Wells College, based on available information. Possible and actual threats to this drinking water source were evaluated. This source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to lakes. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated. (See the section of this document "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected in the drinking water.) The source water assessments are intended to provide managers with additional information for

Inorganic Contaminants							
Lead ³	No	8/16/18	Range 0.642-13.1 6.02 ³	ug/L	0	AL=15	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper ²	No	8/16/18	Range 0.111-0.689 0.635 ²	mg/L	1.3	AL=1.3	Corrosion of household plumbing systems; Erosion of natural deposits.
Barium	No	10/03/24	0.024	Mg/l	2	2	Discharge from metal refineries and drilling wastes and erosion of natural deposits
Nitrate	No	10/03/24	0.94	Mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage, erosion of natural deposits
Sulfate	No	10/03/24	58	Mg/l	N/A	250	Naturally occurring
Fluoride	No	10/03/24	0.11	Mg/l	N/A	2.2	Erosion of natural deposits
Synthetic Organic Contaminants							

Disinfection Byproducts							
Total Trihalomethanes	No	Quarterly	Range 29.3-79.9 LRAA 64 ⁴	ug/L	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids	No	Quarterly	11.3-25.4 LRAA 21 ⁴	ug/L	N/A	60	By product of drinking water chlorination needed to kill harmful organisms.

Notes:

1 – Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement for the year occurred on 4/8-9/23 (0.99). State regulations require that turbidity must always be below 5 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 1.0 NTU.

2 – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value was the 0.635 mg/l value. The action level for copper was not exceeded at any of the sites tested.

3 – The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the 10 sites tested.

4 – This number represents the Highest Locational Running Annual Average (LRAA) for 2023.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminations.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

WHAT DOES THIS INFORMATION MEAN?

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Aurora is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials
--

within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact The Village of Aurora DPW, (315) 364-5239. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2023 our system was in compliance with applicable State drinking water operating, monitoring, and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water exceeded State and Federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the **Safe Drinking Water Hotline (800-426-4791)**.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life.
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.
You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:
 - ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
 - ◆ Turn off the tap when brushing your teeth.
 - ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
 - ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. **Please call our office if you have questions at (315) 364-5239.**